



Certificate No. : TC-5389

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org




Web : http://www.erda.org



## TEST REPORT

ULR-TC538920000012435F

SHEET 01 OF 05

<b>NAME AND ADDRESS OF CUSTOMER</b>  <b>INTEGRA ENGINEERING INDIA LTD.</b> P.O. BOX-55, CHANDRAPURA VILLAGE, TA-HALOL, DIST.-PANCHMAHALS-389350.	<b>TEST REPORT NO.:</b> RP-2021-003803 <b>DATE:</b> 26/06/2020	
	<b>CUSTOMER REF. NO.</b> Letter	<b>DATED</b> 22/06/2020
	<b>DATE OF SAMPLE RECEIPT</b> 22/06/2020	<b>DATE OF TESTING</b> 23/06/2020 to 25/06/2020
	<b>SAMPLE DESCRIPTION</b>  <b>CONTROL PANEL (I-PANEL)</b>  <b>Rating:</b> Rated Voltage: 415VAC Rated Normal Current: 63A, No. of phases: 3+N, Rated frequency: 50Hz, Rated insulation voltage: 1000V  <b>Containing:</b> Contactor, MCB, Push button, Terminal blocks	
<b>SAMPLE IDENTIFICATION</b>  <b>ERDA Sample Code No.:</b> ERDA-00369485  <b>Model No.:</b> 12201010  <b>Manufacturer:</b> M/s. Integra Engineering India Ltd.		
<b>TEST DETAILS</b>  1.0 IP 55 (Category 2) tests  <b>Enclosures:</b> i) Photograph No.: 2021-001096/00369485/A to C (Total 3 nos.) ii) Drg. No.: 12201010 (REV. 00) (Sheet 01 of 05), (Sheet 02 of 05), (Sheet 03 of 05), (Sheet 04 of 05) & (Sheet 05 of 05) (Total 05 sheets)  <b>Test witnessed by:</b> Mr. Amit Dave (EA to CEO) of M/s. Integra Engineering India Ltd.  <b>Note:</b> Structure joints were sealed with silicon sealant.  <b>Remarks:</b> Sample <b>conforms</b> to the requirement of IP 55 (Category 2) tests as per the standard.		<b>TEST SPECIFICATION</b>  Cl. No. 10.3 of IEC 61439-1:2011 & IEC 61439-2:2011
 <b>PREPARED BY</b>	 <b>CHECKED BY</b>	 <b>(G. SOM)</b> <b>APPROVED BY</b>

- Note:**
- This report relates only to the particular sample received for testing in good condition at ERDA, Vadodara.
  - This report cannot be reproduced in part under any circumstances.
  - Publication of this report requires prior permission in writing from Director, ERDA.
  - Only the tests asked for by the customer have been carried out.
  - In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.
- Caution:** ERDA is not responsible for the authenticity of photocopied or reproduced test reports.  
ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TC 2975644