



Certificate No. : TC-5389

## ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org




Web : http://www.erda.org



### TEST REPORT

ULR-TC538920000018859F

SHEET 01 OF 06

<b>NAME AND ADDRESS OF CUSTOMER</b>		<b>TEST REPORT NO.:</b> RP-2021-012079	
<b>INTEGRA ENGINEERING INDIA LTD.</b> P.O.BOX-55, CHANDRAPURA VILLAGE, TA-HALOL, DIST-PANCHMAHALS-389 350.  <b>Manufactured by:</b> M/s. Integra Engineering India Ltd.		<b>DATE:</b> 10/09/2020	
		<b>CUSTOMER REF. NO.</b>	<b>DATED</b>
		Letter	04/09/2020
		<b>DATE OF SAMPLE RECEIPT</b>	<b>DATE OF TESTING</b>
		04/09/2020	08/09/2020 to 09/09/2020
<b>SAMPLE DESCRIPTION</b>		<b>SAMPLE IDENTIFICATION</b>	
<b>CONTROL PANEL (I-PANEL)</b>  <b>Rating:</b> Rated voltage: 415V AC Rated normal current: 32A No. of phases: 3+N Rated Frequency: 50Hz Rated insulation voltage: 1000V  <b>Containing:</b> MCB, Contactor, Terminal blocks, Push buttons		<b>ERDA sample code no.:</b> ERDA-00378976  <b>Model No.:</b> 80208010	
<b>TEST DETAILS</b>		<b>TEST SPECIFICATION</b>	
1.0 IP 65 tests		Cl. No. 10.3 of IEC 61439-1:2011 & IEC 61439-2:2011	
<b>Enclosures:</b> i) Photograph No.: 2021-004186/00378976/A to D (Total 4 nos.) ii) Drg. No.: As per SHEET 02 OF 06.			
<b>Test witnessed by:</b> Mr. Amit Dave (EA to CEO) from M/s. Integra Engineering India Ltd.			
<b>Note:</b> Structure joints were sealed with silicon sealant.			
<b>Remarks:</b> Sample <b>conforms</b> to the requirement of IP 65 tests as per the standard.			
 <b>PREPARED BY</b>		 <b>CHECKED BY</b>	
		 <b>(V.B.PARMAR)</b> <b>APPROVED BY</b>	

- Note:**
1. This report relates only to the particular sample received for testing in good condition at ERDA, Vadodara.
  2. This report cannot be reproduced in part under any circumstances.
  3. Publication of this report requires prior permission in writing from Director, ERDA.
  4. Only the tests asked for by the customer have been carried out.
  5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

**Caution:** ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TC 2999434